

**Per- and polyfluoroalkyl substances (PFAS) have No Federal Maximum Contaminant Level as of December 31, 2020**

**Laboratory Method Detection Level (MDL) for PFAS's are**

Analytical Units ug/L (ppb) part per billion

PFOS	0.04	or	40 ppt parts per trillion (ng/L) nanograms/liter
PFOA	0.02		
PFBS	0.09		
PFNA	0.02		
PFHpA	0.01		
PFHxS	0.03		

**State of Montana has the following Human Health Standards**

Analytical Units ug/L (ppb)

PFOS	0.07	or	70 ppt parts per trillion (ng/L) nanograms/liter
PFOA	0.07		

**OUR WATER WAS SAMPLED IN MAY 2015 AND NOVEMBER 2015**

**Well 42 TP (Palmer St.)**

PFOS	ND
PFOA	ND
PFBS	ND
PFNA	ND
PFHpA	ND
PFHxS	ND

**Well 24 EP (Pattee Creek 50)**

PFOS	ND
PFOA	ND
PFBS	ND
PFNA	ND
PFHpA	ND
PFHxS	ND

**Well 10 TP (Hilda Ave.)**

PFOS	ND
PFOA	ND
PFBS	ND
PFNA	ND
PFHpA	ND
PFHxS	ND

**Well 27 TP (26<sup>th</sup> St.)**

PFOS	ND
PFOA	ND
PFBS	ND
PFNA	ND
PFHpA	ND
PFHxS	ND

**Well 20 TP (Catlin St.)**

PFOS	ND
PFOA	ND
PFBS	ND
PFNA	ND
PFHpA	ND
PFHxS	ND

**Well 02 TP (14<sup>th</sup> St.)**

PFOS	ND
PFOA	ND
PFBS	ND
PFNA	ND
PFHpA	ND
PFHxS	ND

**Well 21 TP (E. Central Ave.)**

PFOS	ND
PFOA	ND
PFBS	ND
PFNA	ND
PFHpA	ND
PFHxS	ND